

**CITY OF SAN ANTONIO  
DEPARTMENT OF CAPITAL IMPROVEMENTS MANAGEMENT SERVICES  
CONTRACT SERVICES DIVISION**

RECEIPT OF ADDENDUM NUMBER **FOUR** IS HEREBY ACKNOWLEDGED FOR PLANS AND SPECIFICATIONS FOR CONSTRUCTION OF **Bonnie Connor Park (Hausman Phase III (40-00089))** FOR WHICH BIDS WILL BE OPENED ON **Tuesday, April 19, 2011** THIS ACKNOWLEDGEMENT MUST BE SIGNED AND RETURNED WITH THE BID PACKAGE.

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_

City/State/Zip Code: \_\_\_\_\_

Date: \_\_\_\_\_

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Print Name/Title

# RVK

## ADDENDUM

---

Project: Bonnie Connor Park  
(Hausman Phase III)  
San Antonio, Texas

Addendum No: Four

Owner: City of San Antonio  
CIMS - Vertical - Parks Division  
P. O. Box 839966  
San Antonio, Texas

Date of Issuance: April 12, 2011

Architect: RVK, Inc.  
745 E. Mulberry, Suite 601  
San Antonio, TX 78212

RVK Project No.: 09076P

---

This addendum is hereby made a part of the construction documents to the same extent as though it were originally included therein. This addendum shall take precedence over the original construction documents where its provisions apply.

---

Item No.      Description:

---

### QUESTIONS AND CLARIFICATIONS

1. Question: There is no power shown for irrigation system. Please clarify where power is coming from.  
**Answer:** "Per specification section 02442, 3.02, I, 4; Hardwire controller to power source; existing electrical panel, located directly adjacent to weather sensor and controller locations shown on Sheet IR1.00 (near the corner of Woller Road and Hausman Road), and verified per on-site pre-bid meeting existing conditions observations."

**END OF ADDENDUM NO. FOUR**

