

CITY OF SAN ANTONIO  
INSPECTORS & SURVEYOR'S OFFICE PROJECT

PROJECT NAME: **COSA Northeast Service Center Fleet Bluiding 2<sup>nd</sup> Floor - (#40-00223)**  
DATE: December 2, 2011

ADDENDUM NO.: **FIVE (5)**

This addendum shall be included in and be considered part of the plans and specifications for the above-referenced project. The Contractor shall be required to sign an acknowledgment of the receipt of this addendum at the time he receives it.

Addendum No. 5 consists of 1 page(s) (including this page).

1. **Question: Is there to be a fire alarm system or is it to connect into the existing fire alarm system? If it is to connect to the existing alarm system, what about the warranty?**

Answer: Please see MEP drawing E3.01, Fire Alarm Note #2 and Key Note #2 specifies that any additional equipment required of the drawings will be added to the existing fire alarm system.  
The warranty will be only for the equipment and wiring installed as specified in Section 16721 FIRE ALARM SYSTEM under the Warranty section.

2. **Question: What type of modifications are to be done to the existing fire sprinklers?**

Answer: Please see P1.01 General Note #1.

3. **Question: What is the status of the building permit?**

Answer: Building permit has been approved and the permit has been paid for by the city.


4. **Question: When is the last day to submit questions?**

Answer: Tuesday, December 6, 2011



---

END OF ADDENDUM NO. 5



DEBRA J. DOCKERY, ARCHITECT, PC

TRANSMITTAL

December 2, 2011

CITY OF SAN ANTONIO

**COSA NORTHEAST SERVICE CENTER FLEET BUILDING 2<sup>nd</sup> FLOOR-(#40-00223)**

**ADDENDUM NO. 5: December 2, 2011, 1 page (not including this cover).**

Please sign below to acknowledge receipt of Addendum No. 5 and return a signed copy to this office by facsimile or email. Unless specifically requested no other copy of these addenda will be sent.

Acknowledgment

---

Signature

Date

---

Type or Printed Name

---

Company Name

118 Broadway, Suite #516, San Antonio, Texas  
Phone: 210-225-6130 Fax 210-225-7588

[www.debradockeryarchitects.com](http://www.debradockeryarchitects.com)