



City of San Antonio

ADDENDUM III


SUBJECT: 6100003227, Formal Invitation for Bid, Annual Contract for Purchase, Installation & Maintenance of Fire Extinguishers, Scheduled to open January 31, 2014, date of issue January 14, 2014.

FROM: Paul J. Calapa, Procurement Administrator

DATE: January 28, 2014

THIS NOTICE SHALL SERVE AS ADDENDUM NO. III - TO THE ABOVE REFERENCED FORMAL INVITATION FOR BID

1. The bid due date is hereby extended to Monday, February 3, 2014.
2. 004 – SPECIFICATIONS/SCOPE OF SERVICES, Item 1: Annual Inspections & Testing – Hydrostatic Testing, statement that read, Fire Extinguisher shall not be removed from building for testing, is here by changed to: **Contractor shall provide a temporary fire extinguisher equal to fire extinguisher being removed for testing so as to not leave building/center without fire extinguisher during testing.**
3. Question No. 5 and Response, Addendum II, posted January 27, 2014 is hereby deleted.



Paul J. Calapa
Procurement Administrator
Finance Department – Purchasing Division