



City of San Antonio

ADDENDUM III

SUBJECT: Formal Invitation for Bid for Annual Contract for Fire Sprinkler Inspection, Maintenance & Repair, (IFB 610006066), Scheduled to Open: October 5, 2015; Date of Issue: September 3, 2015.

FROM: Paul J. Calapa, Procurement Administrator

DATE: October 1, 2015

THIS NOTICE SHALL SERVE AS ADDENDUM NO. III - TO THE ABOVE REFERENCED FORMAL INVITATION FOR BID

THE ABOVE MENTIONED FORMAL INVITATION FOR BID IS HEREBY AMENDED AS FOLLOWS:

1. The IFB submission deadline has been extended to October 9, 2015; 2:00 PM CT.
2. 004 – Specification / Scope of Services, Specific Service Requirements, A. Delivery of Services. Add 25: “The Contractor shall perform higher frequency services at the same time as services required for lower frequency. For example, at the time of performing the annual services (lower frequency); the Contractor shall perform the quarterly, semiannually services so only one trip is required.”
3. Change 004 – Specifications / Scope of Services, *Fire Sprinkler Systems Inspections, testing, and minor maintenance services 3.a.1*, Remove and replace with, “Perform quarterly inspections of gauges, control valves, water flow alarm devices, valve supervisory signal devices, hydraulic nameplate ratings, etc.”
4. Change 004 – Specifications / Scope of Services, *Fire Sprinkler Systems Inspections, testing, and minor maintenance services 3.a.2*, Remove and replace with, “Perform annual inspections of hanger bracing, pipes, fittings, sprinkler heads, spare sprinkler heads, information signs, fire department connections, all valves, etc. and document their condition.”
5. Change 004 – Specifications / Scope of Services, *Fire Sprinkler Systems Inspections, testing, and minor maintenance services 3.b.1*, Remove and replace with, “Perform quarterly inspections of gauges.”
6. Change 004 – Specifications / Scope of Services, *Fire Sprinkler Systems Inspections, testing, and minor maintenance services 3.b.2*, Remove and replace with, “Perform annual inspections of control valves, pressure-regulating devices, piping, hose connections, cabinet, hose, hose storage device, hose nozzle, hydraulic design information signs, hose valves, etc.”
7. Removed Attachment A and replaced with Attachment A – Price Schedule, rev 9-30-15.

****THIS ADDENDUM MUST BE SIGNED AND RETURNED WITH THE BID PACKAGE****



Paul J. Calapa
Procurement Administrator
Finance Department – Procurement Division

Date _____

Company Name _____

Address _____

City/State/Zip Code _____

Signature _____

PC/lj