

CITY OF SAN ANTONIO
CAPITAL IMPROVEMENTS MANAGEMENT SERVICES DEPARTMENT

PROJECT NAME: **COSA Fire Dept. Logistics/Services Facility**

DATE: February 14, 2011

ADDENDUM NO. 7

This addendum shall be included in and be considered part of the plans and specifications for the above named project. The contractor shall be required to sign an acknowledgment of the receipt of this addendum at the time he receives it.

To Drawings and Specifications dated October 18, 2010 for **COSA Fire Dept. Logistics/Services Facility** Prepared By: O'Neill Conrad Oppelt Architects, Inc.

This addendum shall be considered part of the Contract Documents for the above-mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.

Bidders are hereby notified that they shall make any necessary adjustment in their estimates on account of this addendum. It will be construed that each Bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

Total Pages Addendum No. 7: 3

CLARIFICATION:

Item	Reference	Description
CL7-1	Automatic slide gate operators, control arms and card readers, Sheet A-1.1	Provide and install a complete system to operate the gates and arms indicated. Basis of design manufacturer follows: DKS Door King Inc. 1.800.826.7493 2 ea 9150 Slide gate operators. 2 ea 1601 Barrier Arms. 2 ea 1815 Wiegand keypad. 1838 Access Control System. 2 ea 9410 In ground loop.

CL7-2	City of San Antonio Addenda Acknowledgement Form	Add new specification <i>attached herein</i> . Form must be completed, executed for each addendum and included in the proposal.
CL7-3	Concrete Paving Alternate No. 4	Alternate pricing should reflect cost for base bid building footprint only.

SPECIFICATIONS:

Item	Reference	Description
SP7-1	Section 22 1113, 3.2, E, items 1 & 6	Domestic water piping can be type "L".

DRAWINGS:

Item	Reference	Description
D7-1	Sheet C6.4	The A.R.I. 1" D-020 air release valve specified on sheet C6.4 may be substituted with the A.R.I. Model D-025 polycarbonate body combination air release valve.

END OF ADDENDUM NO. 7

**CITY OF SAN ANTONIO
DEPARTMENT OF CAPITAL IMPROVEMENTS MANAGEMENT SERVICES
CONTRACT SERVICES DIVISION**

RECEIPT OF ADDENDUM NUMBER **7** IS HEREBY ACKNOWLEDGED FOR PLANS AND SPECIFICATIONS FOR CONSTRUCTION OF **COSA FIRE DEPT. LOGISTICS/SERVICES FACILITY** FOR WHICH BIDS WILL BE OPENED ON **WEDNESDAY, FEBRUARY 16, 2011 @ 1:00 PM**

THIS ACKNOWLEDGEMENT MUST BE SIGNED AND RETURNED WITH THE BID PACKAGE.

Company Name: _____

Address: _____

City/State/Zip Code: _____

Date: _____

Signature

Print Name/Title