



City of San Antonio
TRANSPORTATION AND CAPITAL IMPROVEMENTS

ADDENDUM No. 5

PROJECT NAME:

INDEFINITE DELIVERY CONTRACT PURCHASE & INSTALLATION OF FENCING

DATE: March 20, 2014

This addendum is separated into sections for convenience; however, all contractors, subcontractors, material men, and other parties shall be responsible for reading the entire addendum. The failure to list an item or items in all affected sections of this addendum does not relieve any party affected from performing as per instructions, providing that the information is set forth one time any place in this addendum. These documents shall be attached to and become part of the Contract Documents for this project. The contractor shall be required to sign an acknowledgement of the receipt of this addendum and submit with their bid.

QUESTIONS/CLARIFICATION ON SPECIFICATIONS:

1. **Question:** On Drawing B-2 of the Specifications, what is the gauge of the terminal post, top rail, and line post?

Response: Schedule 40 is acceptable.

2. **Question:** On Drawing B-8 of the Specifications, the top rail calls for bar channel rail and on Drawing B-12, the top rail calls for U-channel rail. Need Clarification.

Response: Drawing B-8 is correct; there should not be a U-Channel Rail on Drawing B-12.

3. **Question:** There has to be an O.C. for each fence that is quoted by linear feet. If the O.C. is 10' opposed to 20' there is a big difference in price and material.

Response: The Typical O.C. for the steel post and cable is 12.'

4. **Question:** Regarding the pipe and cable fence, need clarification on 3" outside diameter (O.D.). Contacted a supplier and they only carry a 3" inside diameter, which has a 3.5" O.D. or a 2.5" inside diameter, which has a 2.785" O.D. Keep in mind the cap will have a bigger O.D.

Response: 3" inside diameter is acceptable; cap will have a 3.5" outside diameter.

5. **Question:** Specifications indicate Timber Post is 6" in measurement. Aesthetically they will not look as good as a 7" diameter post. Need confirmation.

Response: For Park use, use 6" diameter post.

END OF ADDENDUM No. 5



**City of San Antonio
TRANSPORTATION AND CAPITAL IMPROVEMENTS**

**PROJECT NAME: INDEFINITE DELIVERY CONTRACT: PURCHASE & INSTALLATION OF
FENCING**

RECEIPT OF ADDENDUM NUMBER(S) 5 IS HEREBY ACKNOWLEDGED FOR THE PROJECT:

FOR WHICH BIDS WILL BE OPENED ON: TUESDAY, APRIL 1, 2014 AT 2:00 P.M. CST

*****THIS ACKNOWLEDGEMENT MUST BE SIGNED AND RETURNED WITH THE BID
PACKAGE.*****

Company Name: _____

Address: _____

City/State/Zip Code: _____

Date: _____

Signature

Print Name/Title