

City of San Antonio

ADDENDUM 2

SUBJECT: Formal Invitation for Bid for Fire Sprinkler Inspections and Maintenance Services for the Alamodome, (IFB 6100004633), Scheduled to Open: August 11, 2014; Date of Issue: July 25, 2014

FROM: Paul J. Calapa, Procurement Administrator


DATE: August 7, 2014

THIS NOTICE SHALL SERVE AS ADDENDUM NO. 2 - TO THE ABOVE REFERENCED INVITATION FOR BID

THE ABOVE MENTIONED INVITATION FOR BID IS HEREBY AMENDED AS FOLLOWS:

1. THE IFB OPENING DATE IS HEREBY EXTENDED TO WEDNESDAY, AUGUST 13, 2014, 2:00 PM CENTRAL TIME.
2. Section 004 – Specifications / Scope of Services, ITEM 1 Ca. Annual Fire Line Backflow Preventer Inspection, change to read:
 - a. “Perform annual backflow inspection on each of the five (5) fire backflow devices.
 - I. Model FEBCO 805YDC, Serial #B14180, Size: 10”, Location: NW Fire Room – Field Quad D
 - II. Model FEBCO 805YDC, Serial #B14179, Size: 10”, Location: NE Fire Room – Field Quad A
 - III. Model WILKINS 305A, Serial #U14151, Size: 6”, Location: Warehouse – Lot A
 - IV. Model WATTS 709 DC, Serial #126506, Size: 3”, Location: Boiler Room – Lot A
 - V. Model WATTS 10, Serial #07567, Size: 1 1/2”, Location: Generator Building – Lot A”
3. Remove Attachment A Price Schedule and replace with Attachment A Price Schedule Rev. I dated 8/7/2014, posted as a separate document.

****THIS ADDENDUM SHALL BE SIGNED AND RETURNED WITH THE BID PACKAGE****



Paul J. Calapa
Procurement Administrator
Finance Department – Procurement Division

Date _____

Company Name _____

Address _____

City/State/Zip Code _____

Signature _____